

**K O S H A**KOREA  
OCCUPATIONAL  
SAFETY & HEALTH AGENCY

Ref. Cert. No.

2008-1206-Q1

## Certificate of Approval

Product

Limit Switch

Name and address of the applicant

YOUNG TECH Co., LTD.

(#662-8, Pungmu-Dong, Gimpo-City, Kyunggi-Do, Korea)

Name and address of the manufacturer

Ditto

Name and address of the factory

Ditto

Rating and principal characteristics

Ex d IIC T6 IP67

(AC 250 V 3A, 125 V 5A DC 250 V 0.2 A, 125 V 0.4 A, 30 V 4 A)

AC 250 V 10.1 A, 125 V 10.1 A DC 250 V 0.2 A, 125 V 0.4 A, 30V 4 A / 12~24 VDC, 0~25 VDC / 125 or 250VAC 10A, 480 VAC 2A, 1/8 HP 125 VDC, 1/8 HP 125 VDC, 0.5A 125 VDC, 0.5 A, 125 VDC, Tamb = -20 °C ~ 60 °C)

Trade mark (if any)

Model / Type Ref.

YT-870

Additional information (if necessary)

A sample of the product was tested and found to be in conformity with

Article 33, Industrial Safety &amp; Health Law

The terms of validity

until Oct. 29, 2013

This Certificate of Approval is issued by the KOSHA

Date : Nov. 21, 2008

Oct. 29, 2008 (Original issue)

Signature

President

Noh, Min-Ki