



TEST REPORT

Ref. Report No.

R454-176/03-DEC-2001

Name and address of the applicant

- YOUNG TECH CO., LTD.
- 662-8, Pungmu-Dong, Kimpo-Si,
Kyungki-Do, Korea

Standard / Test regulation

- KSC 0904 (1995)
- IEC 529 2nd Edition (1989)

Test result

- IP 66

Incoming date : 27 NOV 2001

Test date : 03 DEC 2001

Test item(s)

- Electro-Pneumatic Positioner

Model/type ref.

- YT-1000L (Max. DC 24V, 4~20mA)

Manufacturer

- YOUNG TECH CO., LTD.

Additional information

- 19.8 °C, RH 75 %

This test report only responds to the tested sample and shall not be reproduced except in full without written approval of the Korea Testing Laboratory.

Tested and reported by

CHANG-HO, KIM

Reviewed by

WOO-SUP, LEE

KOREA TESTING LABORATORY